



57/816/CDV

**COMMITTEE DRAFT FOR VOTE (CDV)
PROJET DE COMITÉ POUR VOTE (CDV)**

Project number Numéro de projet		IEC 62344 Ed. 1.0	
IEC/TC or SC: TC 57 CEI/CE ou SC:		Secretariat / Secrétariat Germany	
<input checked="" type="checkbox"/> Submitted for parallel voting in CENELEC <input checked="" type="checkbox"/> Soumis au vote parallèle au CENELEC	Date of circulation Date de diffusion 2006-04-28	Closing date for voting (Voting mandatory for P-members) Date de clôture du vote (Vote obligatoire pour les membres (P)) 2006-09-29	
Also of interest to the following committees Intéresse également les comités suivants TC 4		Supersedes document Remplace le document 57/746/CD & 57/782/CC	
Functions concerned Fonctions concernées			
<input type="checkbox"/> Safety Sécurité	<input type="checkbox"/> EMC CEM	<input type="checkbox"/> Environment Environnement	<input type="checkbox"/> Quality assurance Assurance qualité

CE DOCUMENT EST TOUJOURS À L'ÉTUDE ET SUSCEPTIBLE DE MODIFICATION. IL NE PEUT SERVIR DE RÉFÉRENCE.

LES RÉCIPIENDAIRES DU PRÉSENT DOCUMENT SONT INVITÉS À PRÉSENTER, AVEC LEURS OBSERVATIONS, LA NOTIFICATION DES DROITS DE PROPRIÉTÉ DONT ILS AURAIENT ÉVENTUELLEMENT CONNAISSANCE ET À FOURNIR UNE DOCUMENTATION EXPLICATIVE.

THIS DOCUMENT IS STILL UNDER STUDY AND SUBJECT TO CHANGE. IT SHOULD NOT BE USED FOR REFERENCE PURPOSES.

RECIPIENTS OF THIS DOCUMENT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

Title : Hydroelectric power plants - Communication for monitoring and control

Introductory note

The French National Committee will not provide a French translation for this project.

<p>ATTENTION VOTE PARALLÈLE CEI – CENELEC</p> <p>L'attention des Comités nationaux de la CEI, membres du CENELEC, est attirée sur le fait que ce projet de comité pour vote (CDV) de Norme internationale est soumis au vote parallèle. Un bulletin de vote séparé pour le vote CENELEC leur sera envoyé par le Secrétariat Central du CENELEC.</p>	<p>ATTENTION IEC – CENELEC PARALLEL VOTING</p> <p>The attention of IEC National Committees, members of CENELEC, is drawn to the fact that this Committee Draft for Vote (CDV) for an International Standard is submitted for parallel voting. A separate form for CENELEC voting will be sent to them by the CENELEC Central Secretariat.</p>
--	--

Copyright © 2006 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

INTRODUCTION

Editor's notes to this CDV:

This CDV has been preceded by 57/746/CD, published 2005-03-04. Comments are introduced in accordance with 57/782/CC.

The material of this document will be published as addenda to IEC 61850, for later inclusion in the documents. The contents will be divided between the parts of IEC 61850 in basically the following order:

Paragraphs 5 and 6 (informative) – IEC 61850 Part 5

Paragraphs 7 and 8 (normative) – IEC 61850 Part 7-4

Paragraphs 9 and 10 (normative) – IEC 61850 Part 7-3

Appendix A (informative) – IEC 61850 Part 5

Appendix B (normative) – IEC 61850 Part 7-4

For easier understanding and better readability, the present CDV is though for now compiled as one consecutive document.

Compared to the preceding CD (57/746/CD), Paragraph 5 has been expanded into two paragraphs and re-written in order become a self-contained addition to IEC 61850-5. The logical nodes for generator (HGEN) and turbine (HTUR) are now combined into one common logical node HUNT for the complete production unit.

Most of the Logical Nodes defined in this document are not specific for hydropower plants; they can be of use in any type of plant in a power system. This is e.g. the case for all sensor logical nodes.

There have also been some conceptual changes; one such modification relates to the specification of more or less generic logical nodes. Rather than having a number of logical nodes that are named after what they control, the working group decided to name them after the basic algorithm used, or behaviour of the function, and is proposing a prefix naming structure to define what they are controlling. This will make it easier to adopt the logical nodes for automatic control functions to other domains of technology without the need to create new versions of otherwise identical logical nodes.

CONTENTS

1	Scope	6
2	Normative references	6
3	Terms and definitions	7
4	Abbreviations	7
5	Basic concepts for hydropower plant control and supervision	8
5.1	Functionality of a hydropower plant	8
5.2	Principles for water control in a river system	9
5.3	Principles for electrical control of a hydropower plant	9
5.4	Logical structure of a hydropower plant	10
6	Modelling concepts and examples	16
6.1	The concept of Logical Devices	16
6.2	Logical nodes for sensors, transmitters, supervising and monitoring functions	17
6.3	Address strings	18
6.4	Naming of logical nodes	18
6.5	Recommended naming structure for automatic control functions	19
6.6	Summary of logical nodes to be used in hydropower plants	20
6.6.1	General	20
6.6.2	Group A – Automatic control functions	20
6.6.3	Group C – Control functions	21
6.6.4	Group G – Generic references	21
6.6.5	Group H – Hydropower specific logical nodes	21
6.6.6	Group I – Interface and archiving	22
6.6.7	Group K – Mechanical and non-electrical primary devices	22
6.6.8	Group L – Physical devices and common logical nodes	22
6.6.9	Group M – Metering and measurement	23
6.6.10	Group P – Electrical protections	23
6.6.11	Group R – Protection related functions	24
6.6.12	Group S – Supervision and monitoring	24
6.6.13	Group T – Instrument transformers and sensors	24
6.6.14	Group X – Switchgear	24
6.6.15	Group Y – Power transformers	25
6.6.16	Group Z – Power system equipment	25
7	Logical Node Classes	26
7.1	Interpretation of Logical Node tables	26
7.2	Logical Nodes for Automatic Control LN group A	27
7.2.1	Modelling remarks	27
7.2.2	LN: Cooling system control Name: ACSC	27
7.2.3	LN: Curve shape description Name: ACSD	27
7.2.4	LN: Generic Filter Name: AFIL	28
7.2.5	LN: PID reguator NAME: APID	28
7.2.6	LN: Power swing stabiliser Name: APSS	29
7.2.7	LN: RAMP Name: ARMP	30
7.2.8	LN: Generic set-point control Name: ASPT	30
7.2.9	LN: Control high threshold Name: AXTH	31
7.2.10	LN: Control low threshold Name: AXTL	32
7.3	Generic reference Logical Nodes LN group G	32

7.3.1	Modelling remarks	32
7.3.2	LN: Counter Name: GCNT	32
7.3.3	LN: Generic curve model Name: GCRV	32
7.3.4	LN: Generic event signal Name: GEVN	34
7.3.5	LN: Generic variable Name: GVRB	34
7.4	Hydropower specific Logical Nodes LN group H	34
7.4.1	Modelling remarks	34
7.4.2	LN: Turbine - generator shaft bearing Name: HBRG	34
7.4.3	LN: Brake Name: HBRK	35
7.4.4	LN: Combinator Name: HCOM	35
7.4.5	LN: Hydropower dam / reservoir Name: HDAM	35
7.4.6	LN: Dam leakage supervision Name: HDLS	36
7.4.7	LN: Gate position indicator Name: HGPI	36
7.4.8	LN: Dam gate Name: HGTE	36
7.4.9	LN: Intake gate Name: HITG	37
7.4.10	LN: Joint control Name: HJCL	37
7.4.11	LN: Leakage supervision Name: HLKG	38
7.4.12	LN: Water level indicator Name: HLEV	38
7.4.13	LN: Needle control Name: HNDL	39
7.4.14	LN: Water net head data Name: HNHD	39
7.4.15	LN: Dam over-topping protection Name: HOTP	40
7.4.16	LN: Hydropower unit sequencer Name: HSEQ	40
7.4.17	LN: Speed monitoring Name: HSPD	41
7.4.18	LN: Hydropower unit Name: HUNT	41
7.4.19	LN: Water control Name: HWCL	42
7.5	Logical Nodes for interface and archiving LN group I	43
7.5.1	Modelling remarks	43
7.5.2	LN: Safety alarm function Name: ISAF	43
7.6	Logical Nodes for mechanical and non-electric primary equipment LN group K	43
7.6.1	Modelling remarks	43
7.6.2	LN: Fan Name: KFAN	43
7.6.3	LN: Filter Name: KFIL	44
7.6.4	LN: Pump Name: KPMP	44
7.6.5	LN: Tank Name: KTNK	44
7.6.6	LN: Valve control Name: KVLV	45
7.7	Logical Nodes for metering and measurement LN group M	45
7.7.1	Modelling remarks	45
7.7.2	LN: Environmental information Name: MENV	46
7.7.3	LN: Hydrological information Name: MHYD	46
7.7.4	LN: DC measurement Name: MMDC	47
7.7.5	LN: Meteorological information Name: MMET	47
7.8	Logical Nodes for protection functions LN group P	48
7.8.1	Modelling remarks	48
7.8.2	LN: Rotor protection Name: PRTR	48
7.8.3	LN: Thyristor protection Name: PTHF	48
7.8.4	LN: Protection High threshold Name: PXTH	48
7.8.5	LN: Protection Low threshold Name: PXTL	49
7.9	Logical Nodes for supervision and monitoring LN group S	49
7.9.1	Modelling remarks	49

7.9.2	LN: temperature supervision Name: STMP	49
7.9.3	LN: vibration supervision Name: SVBR	50
7.10	Logical Nodes for instrument transformers and sensors LN group T	50
7.10.1	Modelling remarks	50
7.10.2	LN: Angle sensor Name: TANG	51
7.10.3	LN: Axial displacement sensor Name: TAXD	51
7.10.4	LN: Distance sensor Name: TDST	51
7.10.5	LN: Flow sensor Name: TFLW	52
7.10.6	LN: Frequency sensor Name: TFRQ	52
7.10.7	LN: Humidity sensor Name: THUM	52
7.10.8	LN: Level sensor Name: TLVL	52
7.10.9	LN: Magnetic field sensor Name: TMGF	53
7.10.10	LN: Movement sensor Name: TMVM	53
7.10.11	LN: Position indicator Name: TPOS	53
7.10.12	LN: Pressure sensor Name: TPRS	54
7.10.13	LN: Rotation transmitter Name: TRTN	54
7.10.14	LN: Sound pressure sensor Name: TSND	54
7.10.15	LN: Temperature sensor Name: TTMP	54
7.10.16	LN: Mechanical tension /stress sensor Name: TTNS	55
7.10.17	LN: Vibration sensor Name: TVBR	55
7.10.18	LN: Water pH sensor Name: TWPH	55
7.11	Logical Nodes for power system equipment LN group Z	56
7.11.1	Modelling remarks	56
7.11.2	LN: Generator Name: ZGEN	56
7.11.3	LN: Neutral resistor Name: ZRES	56
7.11.4	LN: Semiconductor rectifier controller Name: ZSCR	56
8	Data name semantics	58
9	Common data classes	69
9.1	Device ownership and operator (DOO)	69
9.2	Maintenance and operational tag (TAG)	69
9.3	Operational restriction (RST)	70
10	Data attribute semantics	70
	Annex A (informative) Algorithms in control functions	72
	Annex B (normative) The logical nodes in XML format	78

HYDROELECTRIC POWER PLANTS

Communication for monitoring and control

1 Scope

This document is based on the IEC 61850 series. The document specifies the additional common data classes, logical nodes and data objects required for a hydropower plant. The final document is expected to be included in the IEC 61850 series.

The Logical Nodes and Data Objects defined in this document do belong to the following fields of use:

- **Electrical functions.** This group includes LN and DO used for various control functions, essentially related to the excitation of the generator. New LN and DO defined within this group are not specific to hydropower plants; they are more or less general for all types of larger power plants.

- **Mechanical functions.** This group includes functions related to the turbine and associated equipment. The specifications of this document are intended for hydropower plants, modifications might be required for application to other types of generating plants. Some more generic functions are though defined under Logical Node group K.

- **Hydrological functions.** This group of functions includes objects related to water flow, control and management of reservoirs and dams. Although specific for hydropower plants, the LN and DO defined here can also be used for other types of utility water management systems.

- **Sensors.** A power plant will need sensors providing measurements of other than electrical data. With a few exceptions, such sensors are of general nature and not specific for hydropower plants.

2 Normative references

This document is intended as an addition to IEC 61850. The following referenced documents are indispensable for the application of this document:

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-5, *Communication networks and systems in substations – Part 5: Communication requirements for functions and device models.*

IEC 61850-6, *Communication networks and systems in substations – Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-7-2, *Communication networks and systems in substations – Part 7-2: Basic communication structure for substations and feeder equipment – Abstract communication services interface (ACSI)*

IEC 61850-7-3, *Communication networks and systems in substations – Part 7-3: Basic communication structure for substations and feeder equipment – Common data classes*